

更科系

検査項目		採水場所		更科1号井(原水)								更科2号井(原水)								ろ過器出口				基準値 (mg/L)		更科系給水(野呂田地公園)																		
				R7.4.9	R7.6.25	R7.7.16	R7.10.1					R7.4.9	R7.6.25	R7.7.16	R7.10.1					1号	2号	1号	2号			R7.4.9	(※4)	(※4)	R7.7.16	R7.8.13	R7.9.3	R7.10.1	R7.11.14											
採水年月日				9:30	10:05	10:15	10:10					9:35	10:30	10:35	9:35					R7.7.16	R7.7.16						11:45			13:30	11:50	11:40	12:30	11:45										
採水時刻				午後	晴れ	曇り	晴					晴れ	曇り	晴	晴					9:40	9:50						晴れ			26.1	29.0	32.4	24.1	18.4										
天気				19.5	28.2	27	21.7					19.5	28.0	27.2	21.7					25.5	25.7						22.0			23.0	24.0	24.1	24.1	18.4										
気温 (℃)				16.9	15.7	17.7	15.2					16.6	16.5	17.2	16.4					20.8	17.9						15.0			25.6	27.0	24.8	24.3	17.7										
水温 (℃)																																												
基 準 項 目	1 一般細菌					0								0												100個以下	0			0	0	0	0	0	0									
	2 大腸菌					不検出								不検出												検出されないこと	不検出			不検出	不検出	不検出	不検出	不検出										
	3 カドミウム及びその化合物					<0.0003								<0.0003																<0.0003														
	4 水銀及びその化合物					<0.00005								<0.00005																<0.00005														
	5 セレン及びその化合物					<0.001								<0.001																<0.001														
	6 鉛及びその化合物					<0.001								<0.001																<0.001														
	7 ヒ素及びその化合物					<0.001								<0.001																<0.001														
	8 六価クロム化合物					<0.002								<0.002																<0.002														
	9 亜硝酸態窒素					<0.004								<0.004																<0.004														
	10 シアン化合物イオン及び塩化シアン					<0.001								<0.001																<0.001														
	11 硝酸態窒素及び亜硝酸態窒素					<0.05								<0.02																<0.001	<0.001				<0.001									
	12 フッ素及びその化合物					<0.08								<0.08																<0.08														
	13 ほう素及びその化合物					<0.1								<0.02																1.0以下	<0.1													
	14 四塩化炭素					<0.0002								<0.0002																<0.0002														
	15 1,4-ジオキサン					<0.005								<0.005																<0.005														
	16 ジス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン					<0.001								<0.001																0.04以下														
	17 ジクロロメタン					<0.001								<0.001																0.02以下	<0.001													
	18 トリクロロエチレン					<0.001								<0.001																<0.001														
	19 トリクロロエチレン					<0.001								<0.001																<0.001														
	20 ベンゼン					<0.001								<0.001																<0.001														
	21 塩素酸																			0.25	0.21									0.22	0.27			0.10										
	22 クロロ酢酸																			<0.002	<0.002								<0.002	<0.002			<0.002											
	23 クロロホルム																			<0.001	<0.001								0.06以下	0.002			0.002											
	24 ジクロロメタン																			<0.003	<0.003								0.03以下	<0.003			<0.003											
	25 ジブromクロロメタン																			<0.001	<0.001								0.1以下	0.004	0.004			0.003										
	26 臭素酸																			<0.001	<0.001								0.01以下	<0.001	<0.001			<0.001										
	27 総トリハロメタン																			<0.001	<0.001								0.1以下	0.009	0.009			0.007										
	28 トリクロロ酢酸																			<0.003	<0.003								0.03以下	<0.003	<0.003			<0.003										
	29 ブromジクロロメタン																			<0.001	<0.001								0.03以下	0.003	0.003			0.003										
	30 ブromホルム																			<0.001	<0.001								0.09以下	<0.001	<0.001			<0.001										
	31 ホルムアルデヒド																			<0.008	<0.008								0.08以下	<0.008	<0.008			<0.008										
	32 亜鉛及びその化合物					0.002								<0.001															1.0以下	0.003														
	33 アルミニウム及びその化合物					<0.01								<0.01																0.2以下	<0.01													
	34 鉄及びその化合物					0.16								<0.03						0.08	0.09								0.3以下	0.08				0.08										
	35 銅及びその化合物					<0.01								<0.01																0.01	<0.01													
	36 トリウム及びその化合物					7.6								7.4																200以下	8.8													
	37 マンガン及びその化合物					0.064								0.146						0.003	0.002								0.05以下	0.002														
	38 塩化イオン					4.9								4.8															200以下															
	39 カルシウム、マグネシウム等(硬度)					44								46															300以下	44			6	6	6	6								
	40 蒸発残留物					122								126															500以下	127	124				125									
	41 陰イオン界面活性剤					<0.02								<0.02															0.2以下	<0.000001	<0.000001	<0.000001	<0.000001	<0.000001										
	42 フェノール類					<0.000001								<0.000001															0.00001以下	<0.000001	<0.000001	<0.000001	<0.000001	<0.000001										
	43 2-メチルイソボルネオール					<0.000001								<0.000001															0.00001以下	<0.000001	<0.000001	<0.000001	<0.000001	<0.000001										
	44 非イオン界面活性剤					<0.002								<0.002															0.02以下	<0.002	<0.002					<0.002								
	45 フェノール類					<0.0005								<																														